

e10

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS/School/2022/WZ/ 148

Dated: 29/03/2022

To,

The Principal,  
Rising Star School,  
76/17, Auchandi Road,  
Near Fire Station, Bawana, Delhi-39.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Rising Star School, 76/17, Auchandi Road, Near Fire Station, Bawana, Delhi-39.

Sir,

This has reference to your letter no. nil received via outdoor diary no. 7110 dated 07.03.2022 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 16.03.2022 to see the compliance of the requisite fire safety measures. Sh. Ramesh Kumar was present at the time of inspection.

During the course of inspection it was observed that school building was comprised of Ground floor plus one upper floor. Your request of renewal of FSC is rejected as the following shortcomings were observed:-

1. Temporary structure found constructed in front of staircase which has to be removed for clear passage from staircase.
2. Fire extinguishers provided but not functional.

You are advised to rectify the above-mentioned shortcomings for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully,

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

OUR

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secret. Delhi -54.