

c-25

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE**

**NEW DELHI: 110001**

No. F6/DFS/MS/WZ/2022/EH/277

Dated-31/03/2022

To,

The Joint Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit,  
Police Station, Defence Colony,  
New Delhi.

**Subj.: Issuance of Fire Safety Certificate in r/o M/s. Sandoz Restaurant Located Plot No. 5, 3<sup>rd</sup> Floor, Chun-Mun Store, Aggarwal City Mall, Rani Bagh, Pitampura, New Delhi.**

Sir,

Please refer to online application no 2022022102474 dated 24.02.2022 on the subject cited above. In this connection, it is to inform you that the above said restaurant building has been inspected by the officer concerned of this department on 16.03.2022 in the presence of Sh. Naveen Jha (Manager) to check the shortcomings already pointed out by this department vide letter no. F6/DFS/MS/WZ/2021/597 dated 31.12.2021.

**The statuses of shortcomings are as under:-**

S. no.	Shortcomings	Status
1.	One first aid hose reel is provided instead of requirement 02 nos	Not yet rectified
2.	PA system's speakers found nonfunctional	Removed

In addition to the above, the following shortcomings have been observed during course of inspection.

1. MOEFA is found removed.
2. Door sized is 1.03, 1.45 m & 0.85 m instead two requirement of 1.5 m wide.
3. Temporary structure cover with fiber sheet shall be removed.
4. Open Kitchen running at terrace shall be removed.
5. As per the setup of particular floor seems banquet is running instead of restaurant.
6. One staircase is landing in the hall of second floor & made narrow with ply board structure.

In view of the above shortcoming, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director

29/3/22  
SLC

Copy to: -

1. Sh. Gurmeet Singh, M/s. Sandoz Restaurant Located Plot No. 5, 3<sup>rd</sup> Floor, Chun-Mun Store, Aggarwal City Mall, Rani Bagh, Pitampura, Delhi-110034.
2. The Dy. Health Officer, Keshav Puram Zone, NDMC, Public Health Department, A-1 Block Keshav Puram Zone, Delhi.