

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2022/ *Cons/679*

Dated: 25/03/2022

To,

The Authorized Signatory.
Sky Lark CGHS,
Plot No. 35, Sector – 6, Dwarka.

Subject: Renewal of Fire Safety Certificate in r/o Sky Lark CGHS Located at Plot No. 35, Sector – 6, Dwarka.

Sir,

Please refer to Email dated 20/02/2022 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the team of officers concerned from this department on 14/03/2022 in the presence of Sh. K.K Kapoor (Secretary) for the renewal of fire safety certificate.

During course of inspection the following shortcomings were observed:

1. Six meter wide internal road found not clear.
2. Smoke check Doors found removed in basement.
3. Smoke management system found removed in basement
4. Only one ABC type fire extinguisher of 5kg capacity is found provided at each floor against required two fire extinguishers.
5. Hose reel hose & Hydrant found removed at terrace.
6. Two hoses of 15m length must provided at each floor as per relevant IS code.
7. MOEFA found nonfunctional.
8. PA System found Nonfunctional.
9. Terrace Pump of 450 lpm with 40m head found nonfunctional in auto mode.
10. Exit signage found removed at some places

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

You are requested to comply the abovementioned shortcomings under intimation to this department.

Yours faithfully,


(Anil Garg)
Director

Delhi Fire Service

Copy to:- The Joint Director, DDA, Vikas Sadan, INA, New Delhi.