

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2022/SZ/145

Dated: 29/03/2022

To,

The Manager,
St. Charles School,
Samaspur Khalsa-Ujwa, New Delhi-110073

Sub: - Regarding issuance of Fire Safety Certificate in r/o. St. Charles School, Samaspur Khalsa-Ujwa, New Delhi-110073


Sir,

Please refer to your Application No. Nil dated 21/02/2022 on the subject cited above. In this regard, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 15/03/2022 to see the compliance of the requisite fire safety measures Sh. Kulbhusan (Admin) was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings.

1. First aid Hose reel provided found not functional.
2. Fire pump having 450 lpm output at 30 meters head provided but not functional.
3. Exit Signage's are provided but not sufficient.

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours Faithfully,


Sunil Chawdhary
Dy. Chief Fire Officer
Delhi Fire Service

9/2/22

Copy:-

- The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.