

c56

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI**

No. F6/DFS/MS/MN/2022/EH/269

Dated: 28/03/2022

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit,
Police Station, Defence Colony,
New Delhi,
addecp.lic-dl@nic.in

Subject: Regarding issuance of NOC from fire safety point of view in respect M/s. Standard Sweets & Restaurant Located at B-10/12-A, Rajouri Garden, New Delhi-110027.

Sir,

Please refer to your online application No. 2022011000536 dated 04/02/2022 regarding issuance of Fire Safety certificate in respect of aforesaid restaurant. In this connection, it is to inform you that the premises was re-inspected by officer concerned of this department on 07/03/2022 in the presence of Sh. Anirudh Kumar (Owner/Partner) to check the shortcomings already issued by this department vide letter No. F6/DFS/WZ/2020/347 dated 07/04/2020 & F6/DFS/MS/MN/2021/241 dated 24/05/2021. The status of shortcomings are as under:-

S.N.	Shortcomings	Status
1.	Two Exits of 1.5m each clear width remotest to each other are not provided.	1.77 & 1.40 mts provided instead of 1.50 m each
2.	Hose reel hose of 30 mts length is not provided.	Rectified
3.	MOEFA found not provided.	Rectified but not adequate
4.	Internal Hydrant found not provided.	Rectified
5.	Terrace fire pump of 450 lpm with 40 m found not provided.	Rectified
6.	Overhead water tank of 20,000 ltrs capacity not provided.	Not Rectified (10,000 ltrs is provided instead of 20,000 ltrs)
7.	Exit signages are not provided.	Not Rectified

In view of above shortcomings, pointed at sr. No. 01,03,06, & 07 the application for issuance Fire Safety Certificate is not considered & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Anil Garg)
Director
Delhi Fire Service

Copy to; -

- Mr. Anirudh Kumar Sharma, M/s. Standard Sweets & Restaurant, B-10/12-A, Rajouri Garden, New Delhi-110027
- DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi-110027. (dhowestzone@gmail.com)

o/c SH
25/3/2022