

E-29

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/GH/2022/SZ/ 240(A)

Dated: 28/03/2022

To

The Addl. Commissioner of Police (Lic/Branch),
1st Floor, P.S. Defence Colony,
New Delhi-110049.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s The Solace, located at E-2, East of Kailash, New Delhi-110065.

Sir,

This has reference to with MHA Portal ID 2021112727374 dated 27/11/2021 on the subject above. In this connection, it is to inform you that the premise was inspected by the concern nominated authority of this department on 22/03/2022 in the presence of Mr. Deepak Kumar to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. First Aid Hose reel hose not functional.
2. Fire fighting pumps are not on auto mode.
3. It is requested to comply the fire safety provisions under clause 7.31 of UBBL- 2016 in the building on or before 31/03/2022 in compliance to the notification dated 27/05/2019 an as approved and extended the deadline for compliance time limit by the Hon'ble Minister (UD) vide letter no F5 (189)/AD/ LB/2016/3618-37 dated 20/12/2021.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(SUNIL CHAWDHARY)

DY. CHIEF FIRE OFFICER (SZ)

Copy to

1. The Solace, located at E-2, East of Kailash, New Delhi-110065.