

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SZ/2022/ 665

Dated: 23/03/2022

To,

Sh. Ravinder Deepak,
Manager (Engg-E),
Indian Aviation Academy,
Airports Authority of India, New Delhi 110070

Sub: Regarding issuance of Fire Safety Certificate in r/o Training Centre and Auditorium of Indian Aviation Academy, Vasant Kunj, New Delhi.


Sir,

This was reference to your Gmail of dated 03/03/2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 07/03/2022 in presence of Sh. Ravinder Deepak to ascertain the availability and operability of the fire prevention and fire safety measures. During the course of inspection, the following shortcoming observed were noticed:-

1. Smoke management system not provided in the basement and upper floors.
2. The Auto starting of pumping arrangement found non-functional.
3. The Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to:

1. The Executive Engg. (Bldg.), SDMC, Central Zone, Jal Vihar, Lajpat Nagar, New Delhi-110002