

234

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/School/SZ/2022/160

Dated: 07/04/2022

To

The Principal,
Savitri Public School,
G-314, Sangam Vihar, New Delhi-80.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **Savitri Public School located at G-314, Sangam Vihar, New Delhi-80.**

Sir,

With reference to letter no. SPS/DFS/2022(2)-1 dated 21.02.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 24.03.2022 in the presence of Principal and it was observed that the building is comprised of three blocks: 02 block having Ground + 03 upper floors & 01 block having Basement + Ground + 03 upper floors which are interconnected at each floor level. During the inspection following shortcomings were observed:-

1. Alternate staircase having width not less than 1.5 mtrs must be provided in one of the blocks (having Basement + ground + 03 upper floors)
2. Fire pump 450 LPM & 180 LPM provided against the requirement of 900 LPM & 225 LPM.
3. Overhead tank capacity 5,000 ltrs provided against the requirement of 15,000 ltrs for fire fighting.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.

o/c 07/04/2022