

C-21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2022/158

Dated: 05/04/2022

To

The Secretary,  
Bhai Joga Singh Khalsa Girls Sr. Sec. School,  
East Patel Nagar, New Delhi- 110008.

Sub.: Regarding issuance of Fire Safety Certificate in r/o Bhai Joga Singh Khalsa Girls Sr. Sec. School, East Patel Nagar, New Delhi-110008.

Sir,

Please refer to your letter No. BJSS/Fire Safety/2022/821 dated 21.03.2022, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in presence of Sh. Jaidev Rawat, ASO of the School, on 28.03.2022 to check the status of the shortcomings pointed out by this department vide letter No. F.6/DFS/MS/School/SZ/2018/1794 dated 04.05.2018. But no improvement was observed as seen during the course of inspection and this department has already issued a letter in this matter vide this office letter No. F.6/DFS/MS/School/SZ/2018/3619 dated 24.08.2018.

In view of the above, 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully

(Sunil Chaudhary)

Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

o/c

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

**(with a request to take further action as school does not have fire NOC)**

C-14

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2018/

Dated: -

04/05/18

1794

To,

The Principal,  
Bhai Joga Singh Khalsa Girls Sr. Sec. School,  
East Patel Nagar, New Delhi- 110008.

Sub.-: Regarding issuance of Fire Safety Certificate in r/o Bhai Joga Singh Khalsa Girls Sr. Sec. School, East Patel Nagar, New Delhi-110008.

Sir,

Please refer to your letter No. BJSS/Fire Safety/2018/442 dated 12.03.2018 on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in presence of Ms. Inderjeet Kaur, Incharge of the School on 10.04.2018 to check the status of the shortcomings already issued by this department vide letters dated 07.10.2011 & 19.04.2007.

During inspection, it has been observed that the said school is running at first floor to third floor of the building comprised of ground plus three upper floors, served by single staircase having width 3.0 mts from ground to first floor, 02 nos. of staircase having width 1.28 & 0.90 mts from first floor to second floor and single staircase from second floor to third floor having width 0.90 mt. No fire safety arrangement found provided except few fire extinguishers in the school building. Following fire safety and means of escape arrangements are required:-

1. Alternate staircase shall be extended up to third floor.
2. Terrace pump having capacity 450 LPM is required.
3. Overhead water tank capacity 10000 lts is required exclusively for firefighting purpose.
4. First aid hose reel hose at each floor.
5. Exit signs at places mentioned during the course of inspection.
6. Fire extinguishers are required to be refilled.

In view of the above shortcomings, 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully

*W*  
*2/5*

(VIPEN KENTAL)  
CHIEF FIRE OFFICER

Copy to: -

1. The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi

for information please

*9c*  
*26/4/18*