

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/NDZ/2022/ 811

Dated:- 08 .04.2022

To

The Deputy Director, Admin.,
Central Drugs Standard Control Organization (HQ),
Directorate General Health Services,
Ministry of health and family welfare,
FDA Bhawan, Kotla Road, New Delhi.

Sub: Request for grant of Fire NOC in r/o Food Drugs Administrative Bhawan on Kotla Road,
New Delhi (Near Mata Sundary College).

Sir,


This has reference to your e- mail drugsection@cdsco.nic.in dated 12/03/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by officers concerned of this department on dated 29.03.2022 in the presence of Sh. Ravinder Kumar & Sh. Anuj Panwar and the following shortcomings were observed.

1. Hose reel found non-functional at basement & terrace floor.
2. Terrace level pump found nonfunctional.

Further, 5th floor is temporary constructed, required to be removed or submit the sanctioned plans/regularized plan of the same.

In view of above shortcomings, request for renewal of fire NOC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully


(Anuj Garg)
DIRECTOR
011-23410000

Copy to:

- 1) The Commissioner,
NDMC, Civic Centre, Minto Road,
New Delhi.