

218

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/School/2022/SZ/ 169

Dated: 12/04/2022

To,


The Principal,  
Gayatri Public School,  
Jharoda Kalan, New Delhi-110059.

**Sub:-**Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Gayatri Public School, Jharoda Kalan, New Delhi-110059.

Sir/Madam,

This has reference to your E-mail dated 23/03/2022 on the subject captioned above. In this connection, it is to inform you that the above mentioned building/premises was inspected by the officer concerned of this department on 31/03/2022 in the presence of Sh. Suresh Kumar (Manager) to verify the compliance of shortcoming already communicated by this department vide letter no. F6/DFS/MS/School/2019/SZ/2930 dated 20/05/2019 and observed that shortcomings are still not rectified. The management will be held responsible for any untoward incident for the period if compliance is not made.

Yours faithfully

  
(Sunil Chawdhary)  
Dy.Chief Fire Officer



Copy to:-

1. The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi-110054.

**(With a request to take further action as school does not have fire NOC)**

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2019/SZ 12930

Dated: 20/5/19

To,

The Principal,  
Gyatri Public School,  
Jharoda Kalan, New Delhi-110072

Sub: - Regarding issuance of Fire Safety Certificate in r/o Gyatri Public School, Jharoda Kalan, New Delhi-110072

Sir,

This has reference to your Letter No. Form "J" dated Nil on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 09.04.2019 to see the compliance of the requisite fire safety measures. Sh. Suresh Kumar (Manager) was present at the time of inspection.

During the course of inspection it was observed that school comprised of ground floor in a two storied building was issued Fire Safety Certificate vide letter no. F.6/DFS/MS/School/2015/SZ/236 dated 18.02.2015. Now first floor is also using for school purpose. The following shortcoming was observed:-

1. Door width is 90 to 105 cms against required width of 100 cms on First floor.
  - If student capacity is more than 45 in any class room then double door having width 100 cms are required.

You are advised to rectify the above-mentioned shortcomings for taking further action as necessary for grant of Fire Safety Certificate.

Yours Faithfully,

(ATUL GARG)

CHIEF FIRE OFFICER

Copy to:-

Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi-110054

07/05/19  
10/5/19