

C-15

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS/School/2022/SZ/161

Dated: 07/04/2022

To.

The Manager,  
Hari Krishna Public School,  
A-114-118, Mansa Ram Park,  
Uttam Nagar, New Delhi-110059.

**Sub:** - Regarding issuance of Fire Safety Certificate in r/o. Hari Krishna Public School, A-114-118, Mansa Ram Park, Uttam Nagar, New Delhi-110059.

Sir,

Please refer to your letter No. H/K/P/S dated 15/03/2022 on the subject cited above. In this regard, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 28/03/2022 to see the compliance of the requisite fire safety measures. Sh. Ashok Sharma (Manager) was present and it was observed that the school building is comprised of ground plus three upper floors and have following shortcomings.

1. An additional staircase shall be provided 1.5 m wide.
2. First aid Hose reel not provided at each floor level.
3. Fire pump having 450 lpm output at 40 meters head not provided at terrace level.
4. Overhead water storage tank 10,000 liters not provided
5. Exit Signage's are not provided.

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours Faithfully,

(Anil Garg)  
**Director**

Delhi Fire Service

Copy:-

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi-110054.