

C-11

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No. F6/DFS/MS/EH/2022/NDZ/278

Dated: 31/03/2022

To,

The Joint Commissioner, (Licensing)
Office of the Joint Commissioner of Police (Lic.)
1st floor, Police Station Defence Colony
New Delhi

Subject :-Regarding issuance of Fire Safety Certificate in M/s Jubilant Food works Ltd.(Domino's Pizza), Shop no. B-10, Kh no. 66 & 68 street no. Vill. Sikdar pur west Jyoti Nagar, Delhi-110094

Sir,

With reference to your online application No. 2021123029645 dated 3/1/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned restaurant from fire safety point of view in presence of Mr. Pradeep(Shift Manager). During the course of inspection the following shortcomings were observed.

1. Exit door of 1.0 mtr. wide provided in place of 1.50 mtr.
2. First Aid Hose reel is not provided.
3. MOEFA is not provided.
4. Down-comer is not provided.
5. A fire pump having 450 lpm output of 40 meters head at terrace is not provided.
6. Over head tank 20,000 liters not provided.
7. Standby power supply not provided.
8. Sanctioned plan/ built plan on scale of 1:100 not provided.

In view of above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully


(Anil Garg)
Director

Copy to:-

1. The Manager
M/s Jubilant Foodworks Ltd. (Domino's Pizza)
Shop no.B-10,kh no 66 & 68 Vill. Sikdar pur,
West Jyoti Nagar, Delhi-110094.
MHA ID. 2021123029645 dated 3/1/2022
2. The Commissioner (EDMC)
Plot No.419, Patparganj Industrial Area, Delhi-110092