

c61



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/School/WZ/2022 | 167

Dated: 08/04/2022

To,

The Principal,
St. Matthew's Public School,
A-6, Paschim Vihar, New Delhi-110063.

Sub. :- Renewal of Fire Safety Certificate in r/o St. Matthew's Public School Located at A-6, Paschim Vihar, New Delhi-110063.

Sir,

Please refer to your email dated 14.03.2022 on the subject cited above. In this connection it is to inform you that the said School building has been inspected by the officer concerned of this department on 24.03.2022 in presence of Ms. Anita Sethi (Principal). Fire Safety arrangement such as fire extinguishers, fire aid hose reel, internal hydrant, fire pump etc. found provided.

However, the following shortcomings have been observed:-

1. First aid hose reel found non-functional
2. Terrace pump 450 lpm capacity found non-functional.
3. Overhead water storage tank 5000 ltrs capacity found empty.
4. Exit signages are inadequate.
5. In Lab. LPG cylinder is not allowed.


In view of the above shortcoming, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Education Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.


08/04/22.