

E-35

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/School/2022/NDZ/ 168

Dated 08/04/2022

To,

The Manager,
M.N.B.Modern Sec. School,
Phase-9,Gali No.1,Shanti Nagar Gate,
Shiv Vihar,(Near Metro Station) Delhi-110094.

Sub:- Regarding Issuance Fire Safety Certificate in R/o M.N.B.Modern Sec. School,
Phase-9,Gali No.1,Shanti Nagar Gate, Shiv Vihar,(Near Metro Station) Delhi-110094.

Sir,

With reference to your Letter no.M.N.B/Fire/2022 dated 16/3/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view on dated 26/03/2022 in presence of Mr. Manoj Sharma, (Manager) of the School. The following points / shortcomings were noticed in the building comprised of ground plus two upper floors.

1. Fire Extinguishers not functional at the time of inspection.
2. First-Aid hose reels(01 nos) not functional at the time of inspection.
3. A fire pump having 450 LPM output at 40 meters head not functional at the time of inspection.
4. Over head tank 1,000 liter provided in place of 10,000 liter as required.
5. Exit signage not provided.

In view of above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully


(Sunil Choudhary)
Dy. Chief Fire officer

Copy to:-

The Dy. Director of Education,
B-Block, Yamuna Vihar
Delhi 110053