

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6 /DFS/MS/Industrial/SZ/2022/765

Dated: 05/04/2022

To

M/s Satvik Logistics LLP,
A-24/6, 2nd floor,
Mohan Co-operative Industrial Area/Estate,
New Delhi.

Sub: - Regarding grant of Fire Safety Certificate in r/o **Prem Ratan Rathi, Plot no. 24/6, Block-A, Mohan Co-operative Industrial Area/Estate, New Delhi.**

Sir,

With reference to your letter no. nil dated 16.02.2022 on the subject cited above, it is informed that the said building was inspected by Assistant Divisional Officer (M. Road) from this department on 24.03.2022 in the presence of Mr. Mahesh, party boy and it was observed that the building is comprised of basement + ground + 02 upper floors. During the inspection the following shortcomings were observed: -

1. Fire Check Door (1 hours resistance rating) not provided.
2. First aid hose reel found non functional.
3. Automatic Fire Detection and Alarm System (ADAS) found not provided in basement, ground & first floor.
4. Sprinkler system found not provided at 2nd floor.
5. NRV not provided on terrace.
6. Heavy leakage in pump room.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Executive Engineer (Building), South DMC, 9th floor, Dr. SPM Civic Centre, JLN Marg, New Delhi.