

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/School/2022/ 163

Dated: 07/04/2022

To,

The Principal,  
 R. K. Memorial Public School,  
 Karan Vihar, Ph-V, Kirari, Suleman Nagar,  
 Delhi-86.

**Sub:** Renewal of Fire Safety Certificate in r/o R. K. Memorial Public School, Karan Vihar, Ph-V, Kirari, Suleman Nagar, Delhi-86.

Sir,

This is in reference to your letter No. RKMP/2021-22/02/461 dated 22.02.2022 received through outdoor diary no. 6777 dated 22.02.2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **24.03.2022**, in presence of **Mr. Jitneder, (Teacher)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (4) of Rule 37 of DFS Rules-2010 due to following reason:

1. 6000 ltrs Over Head water captive tank provided against the required capacity of 10,000 ltrs.
2. Additional construction found to be carried out on terrace of third floor.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:  
[http://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)  
[http://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms)

Yours faithfully

(Dhrampal Bhardwaj)  
 Dy.Chief Fire Officer  
 Tel:-01123414250

OK  
 07/04/2022