

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/2022/ 810

Dated:-08/04/2022

To,

The Estate Manager,
Surya Kiran Building,
B-12, K.G. Marg, New Delhi.

Sub:- Renewal of fire safety certificate in r/o Surya Kiran Building, B-12, K.G. Marg, New Delhi.

Sir,

This has reference to your e-mail <skms_main@yahoo.com> dated 21.03.2022 on the subject cited above. In this regard, it is to inform that the site was inspected by the officers concerned of this department on 25/03/2022 in the presence of Sh. Madhu Sudan and the following shortcomings were observed: -

1. Fire check doors not provided at 13th floor.
2. Smoke management system is not provided at second basement.
3. Detectors found nonfunctional at some floors.
4. Electrical shafts are not sealed properly at floor levels.

In view of above shortcomings, request for renewal of fire NOC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully,

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:

The Chief Architect,
New Delhi Municipal Council, Palika Kendra, New Delhi.