

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

c57

No. F6/DFS/MS/2022/SZ/ School/170

Dated: 12/04/2022

To,

The Executive Engineer (Building),
MCD Zone officer, Najafgarh,
Dhansa bus stand Najafgarh,
New Delhi.

Subject: Renewal of Fire safety Certificate in r/o Venkateshwar International School, Located at Sector 10, Dwarka, New Delhi 110075

Sir,

Please refer to party Email dated 10/03/2022 on the subject mentioned above. In this connection it is to inform that this department has already requested your office vide letter of even no. F6/DFS/MS/SZ/2021/515 dated 27/09/2021 (copy enclosed) to measure the height of the building so that further action to renew the Fire Safety Certificate may be taken accordingly. But no reply is received in this office till date.

In view of above once again you are requested to measure the height of the building and inform to this department so that further action may be taken at our end.

Yours faithfully,

Enclosed:- As above

(Atul Garg)
Director,

Delhi Fire Service.

Copy to: - The Principal Venkateshwar International School, Located at Sector 10, Dwarka, New Delhi 110075.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2021/515

Dated.27/09/2021

To,

The Executive Engineer (Building),
MCD Zone officer, Najafgarh,
Dhansa bus stand Najafgarh,
New Delhi.

Subject: Request to verify the height of the Building Venkateshwar International School, Located at Sector 10, Dwarka, New Delhi 110075


Sir

This has reference of party letter / Email Dated 10/08/2021 for the renewal of fire safety certificate in r/o above mentioned school.

In this regard it is to inform you that inspection of the above said school was carried out by the officer concerned from this department on 25/08/2021 and observed that the school has constructed 3 temporary Rooms on the terrace.

In view of the above it is requested that height of the school building may kindly be measured and informed to Delhi Fire Service for taking further action at our end.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service

Copy to:-The Principal Venkateshwar International School, Located at Sector 10, Dwarka, New Delhi 110075.