

C-36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/School/2022/NDZ/ 174

Dated 13/4/2022

To,

The Principal,
EDMC Nigam Pratibha Vidyalaya,
Krishna Nagar, Shahdara South,
Delhi- 110051

Sub:- Regarding Issuance Fire Safety Certificate r/o EDMC Nigam Pratibha Vidyalaya located at Krishna Nagar, Shahdara South, Delhi- 110051.

Sir,

This is in reference to your letter No. nil dated 09/03/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of Mr. Sukhdev Singh, Teacher of the School. The following points / shortcomings were noticed in the building which is comprised of ground plus three upper floors.

1. First-Aid hose reels not provided.
2. Fire pump having 450 LPM output with 40 meter head not provided on terrace.
3. Exit signs are required to be provided in the school building at all exits.

In view of above, the building can not be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

olc

2.

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92