

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

C37

No.F6/DFS/MS/School/NDZ/2022/171

Dated:- 13/04/2022

To

The Principal,
Gautam Modern School,
Mayur Vihar, Phase-III, Delhi – 110096.

Sub: Regarding Renewal of FSC in r/o Gautam Modern School located at Mayur Vihar Phase-III, Delhi-91.

Sir,

This has reference to your letter no. GMS/474/2022 dated 15/03/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 25/03/2022 in the presence of Mr. Pardeep Gautam and the following shortcomings were observed :-

1. Fire pump capacity of 280 LPM provided against required capacity of 450 LPM.
2. Temporary structure/rooms constructed at terrace floor be removed.

Hence, the Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings under the intimation to this department for further necessary action in this regard.

Yours faithfully



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Stc
m

Copy to:-

The Dy. Director of Education,
EDMC, Udyog Sadan,
Plot No. 419, FIE, Patparganj, Delhi-92.