



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

C-32

No. F6/DFS/MS/SZ/2022/ School / 175

Dated: 13/04/2022

To,

The Assistant Engineer (E),
Sub Div – 1 Education Divn M 1 (N),
PWD GNCT, Govt. of Delhi,
ITI Campus, Pusa, New Delhi.

Subject: Renewal of Fire Safety Certificate in r/o Govt. Sarvodaya Kanya Vidyalaya, Located at
No-01 Palam Enclave New Delhi.110045.(School ID-1821018)

Sir,

Please refer to letter no 54(SPS School)/PWD Edu.Sub-Divn M1-1(N)2021-22/06 Dated-
21/02/2022 on the subject mentioned above. In this connection it is to inform you that the premises was
inspected by the officer concerned from this department on 23/03/2022 in the presence of Mr. Punit
Dutta.

During the course of inspection following shortcoming is observed.

1. Width of Class Door is 112 cm against required 120 cm.

However the terrace fire pump 450 LPM & ABC type fire extinguishers at each floor, terrace
tank of 10,000 ltr capacity, Hose Reels at each floors are found provided in the premises.

You are requested to comply the abovementioned shortcoming under intimation to this
department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.


Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054
2. The Principal, Govt. Sarvodaya Kanya Vidyalaya, No-01, Palam Enclave New
Delhi.110045.


12/4/22