

c. 37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2022/SZ/ 290

Dated: 12/04/2022

To

The Dy. Health Officer,
Public Health Department, SDMC,
Green Park, Aurobindo Marg,
New Delhi 110016


Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o High Street (A Unit of Spize Hospitality) Situated at First Floor, 32, Basant Lok complex, Vasant Vihar, New Delhi 110057.

Sir,

This is in reference to with MHA Portal Id No 2022012901340 dated 29/01/2022 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 02/04/2022 in the presence of Mr. Mithlesh and observed that the shortcoming intimated vide letter of even no. 149 dated 04/04/2021 has not been complied yet. (Copy Enclosed for ready reference).

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)

DY. CHIEF FIRE OFFICER (SZ)

Copy to

1. High Street (A Unit of Spize Hospitality) Situated at First Floor, 32, Basant Lok complex, Vasant Vihar, New Delhi 110057.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6 DFS/MS/EH/2021/ 149

Dated 01/04/2021

To

The Dy. Health Officer,
 SDMC, South Zone,
 Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s High Street (A Unit of Spize hospitality) situated at 1st floor, 32, Basant Lok Complex, Vansant Vihar, New Delhi - 110057

Sir,

This has reference to your online I. D. No. 20210022010620 dated 21/02/2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 15.03.2021 in the presence of Mr. Ajay Mishra (Manager) to verify the fire safety measures installed in the building and observed that the building is comprised of Basement, ground + mezzanine + 03 upper floors and restaurant is running at First floor only. During inspection, following points were observed:

- 1 There one staircases having width of 1.10 mtr against the required two staircases having width of 1.50 mtr each.
- 2 There are only one door having width of 1.10 mtr against the required of two having width of 2.0 mtr & 1.50 mtr respectively.
- 3 Hose reel not provided.
- 4 MOEFA not provided.
- 5 Internal Hydrants not provided.
- 6 Terrace level Fire Pump capacity of 450 LPM not provided.
- 7 Underground tank capacity 1, 00,000 ltrs not provided.
- 8 Overhead tank capacity 5,000 ltrs not provided.

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You may apply again on form 'I' as stipulated in sub rule (2) 35 of rules, DFS Rules 2010 after compliance of the shortcoming mention above. The link for forms is as under available on <http://delhi.gov.in./wps/wcm/connect/doit/fire/FIRE/Home/Forms>.

Yours faithfully

(Atul Garg)
 Director

Copy to:

1. Joint C P (Lic.) P.S. Defence Colony, New Delhi (Ref. Application no. 20210022010620 dated 21/02/2021)
2. The Authorized Signature, M/s High Street (A Unit of Spize hospitality) situated at 1st floor, 32, Basant Lok Complex, Vansant Vihar, New Delhi - 110057