

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2022/SZ/ 274
To

Dated: 07.04.2022

The Joint Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding issuance of FSC/NOC in r/o M/s Khanna Residency located at Plot No G-4, Saket, New Delhi 110017.

Sir,

This is in reference with MHA Portal ID 202032103909 dated 21/03/2022 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 30.03.2022 in the presence of Mr. Sunil Sharma (Manager) of the Guest House. During the inspection, it was observed that the Guest House is running Ground + Three Upper Floors. The shortcomings observed are as below:

1. Fire check doors not provided in the building as per clause 7.31 of UBBL 2016.
2. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
3. Terrace level Fire Pump capacity of 450 LPM provided but not working.
4. Overhead tank capacity 2000 ltrs provided against the required capacity of 2,500 ltrs and the fire tank is also being used for domestic purposes.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to:-

1. M/s Khanna Residency located at Plot No G-4, Saket, New Delhi 110017.