

C-22

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2022/NDZ/ 178

Dated 18/4/2022

To,

The Principal,
Nigam Pimary CoEd. School,
West Azad Nagar, Shahdara South,
Delhi- 110051

Sub:- Regarding Issuance Fire Safety Certificate r/o Nigam Pimary CoEd. School located at West Azad Nagar, Shahdara South, Delhi- 110051.

Sir,

This is in reference to your letter No. EDMC//SH(S)/PS/WAN/2022/389 dated 14/03/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view in presence of Mrs. Neeraj Singhal, Principal of the School. The following points / shortcomings were noticed in the building which is comprised of ground plus three upper floors and two separate block of ground plus one & ground plus three.

1. One additional staircase of width 1.50 meter is required in the building.
2. First-Aid hose reels not provided.
3. Fire pump having 450 LPM output with 40 meter head not provided.
4. Exit signs are required to be provided in the school building at all exits.

In view of above, the building can not be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully


(Atul Garg)
Director

Delhi Fire Service

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92

o/c
2