

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F6/DFS/MS/2022/WZ/ *School /180*

Dated: *18/4/2022*

To,

The Principal,  
North Delhi Municipal Corporation Primary School,  
Sri Nagar, Old-2, Keshavpuram Zone (Ward no. 70),  
Delhi.

**Subj:- Regarding renewal of Fire Safety Certificate in respect of North Delhi Municipal Corporation Primary School Located at Sri Nagar Old-2, Keshavpuram Zone, Delhi.**

Sir,

This has reference to your letter no nil dated nil on the subject cited above. In this connection, it is to inform you that the said school building was re-inspected by the officer concerned of this department on 24.03.2022 in the presence of Ms. Prabha Tyagi (Principal).

During the inspection, it was observed that the building is comprised of Ground + 02 Upper Floors. Fire Safety arrangements such as fire extinguishers, first aid hose reel, fire pump etc found provided. However, the following shortcomings have been observed:-

1. A Terrace pump of 450 lpm capacity found non-functional.
2. First Aid Hose reel found non-functional.
3. Overhead water storage tank 2000 ltrs capacity found damaged instead of requirement 10,000 ltrs.
4. 06 nos ABC type of Fire extinguisher is not provided.

In view of the above shortcoming, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Education Authority may take suitable necessary action as deemed fit

Yours faithfully,

*(Signature)*  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054