

c-59

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/GH/2022/SZ/ 282

Dated: 12/04/2022

To

The Joint Commissioner of Police,  
Lic (Branch) 1<sup>st</sup> Floor, P S Defence Colony,  
New Delhi 110049.


**Sub:** Regarding issuance of Fire Safety Certificate (FSC) in r/o M/s Shiv Guest House Situated at H-2, Green Park Extension, New Delhi 110016.

Sir,

This is in reference to with MHA Portal Id No 2022030403077 dated 08/03/2022 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 08/03/2022 and observed that the shortcoming intimated vide letter of even no. 147 dated 09/02/2021 has not been complied yet. (Copy Enclosed for ready reference).

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)

DY. CHIEF FIRE OFFICER (SZ)

Copy to

1. M/s Shiv Guest House Situated at H-2, Green Park Extension, New Delhi 110016.

C-53

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

**NO. F-6/DFS/HQ/ 2020/ 147**

**Dated 09/02/2021**

To

09/02/2021

The Joint Commissioner of Police / Lic.  
1st floor, Police Station  
Defence Colony, New Delhi.

**Sub: - Regarding issuance of fire safety certificate in r/o M/s Shiv Guest House situated at H-2, Green Park Extension, New Delhi-110016.**


Sir,

This has reference to your online request I D. No. 2019102200223 Dated: 20.05.2020 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 03.12.2020 in the presence of Sh.Biju, Manager to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. Fire Safety Certificate issued vide letter no. 623 dated 26.03.2019 for basement, ground and two upper floors. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

- 1 Fire check doors not provided in the building as per clause 7.31 of UBBL 2016.
- 2 Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
- 3 Temporary structure seen at terrace level, which is not allowed as per clause 7.31 of UBBL02016.

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You may apply again on form 'J' as stipulated in sub rule(2) 35 of rules .DFS Rules 2010 after compliance of the shortcoming mention above. The link for forms is as under available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.

Yours faithfully



(Sunil Chowdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to :

M/s Shiv Guest House situated at H-2, Green Park Extension, New Delhi-110016.