

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-8

No. F6/DFS/MS/SCHOOL/MN/ 2022 / 176

Dated: 18/04/2022

To

The Principal,
Swami Sivananda Memorial Sr. School,
Punjabi Bagh,
New Delhi-110026.

Sub: - Regarding issuance of fire safety certificate in r/o Swami Sivananda Memorial Sr. School, Punjabi Bagh, New Delhi-110026.

Sir,

This is in reference to your letter No. SSMSS/2022/1103 dated 09/03/2022, on the subject cited above. In this connection, it is to inform you that the School Building was inspected by the officer concerned of this department on 28/03/2022 in the presence of Smt. Renu Singh (Incharge) to check the status of earlier shortcomings already issued by this department vide letter No. F.6/DFS/MS/2011/School/2652 dated 21/10/2011.

During Inspection it has been observed that the above School is running G + 01 Upper floor in a building comprised of Ground + 01 upper floor (Educational Block). Total three units are running in same premises. One more school building comprised of Ground + 02 is there. Total four blocks are in the same premises. 1st Building is Ground + 1 (Swami Sivananda Memorial Sr. School), 2nd Building is Ground + 02 (Vocational Training Centre) & 3rd Building is Ground floor (Primary School) & 4th Building is Ground + 02 under construction. Fire safety arrangements Such as First Extinguisher, etc are provided. However the Status of Shortcomings are as under.

| S. no. | Shortcomings | Status |
|--------|---|--|
| 1. | Three units are running in same premises. The plot area and covered area of the individual unit may be intimated. | Not- Rectified |
| 2. | The fire extinguisher provided was found empty and inadequate. | Rectified |
| 3. | The Secondary school is having single staircase of 125 cm against the two staircases. | Not -Rectified (if one stair is less than 1.5 mtr then second stair of 0.75 mtr is to be provided. |

In view of above, the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The education authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.

18/04/2022

C-5 (3)

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2011/school/2652

Date: 21 / 10 / 2011

To

✓
The Vice Principal,
Swami Sivananda Memorial Secondary School,
Punjabi Bagh,
New Delhi-110026

Sub: -Regarding issuance of NOC from fire safety point of view in respect Swami Sivananda Memorial Secondary School, Punjabi Bagh, New Delhi-110026 (Code- 1515082).

Please refer to letter No SSMSS/2375 Dated 26/05/2011 on the subject cited above. In this connection the premises was visited by the officer of this department and observed that the premise is having three sections. First is Secondary School having Ground + one floor is having single staircase of 125 cms. Second section is Vocational Institute and the third is primary section having ground floor only.

During inspection following shortcomings were observed.

1. Three units are running in same premises. The plot area and covered area of the individual unit may be intimated.
2. The fire extinguishers provided were found empty and inadequate.
3. The Secondary school is having single staircase of 125 cms against the two staircases.

The premise is **not meeting** the requirements of Director of Education Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011.

In view of above No objection certificate from fire and safety point of view cannot be considered at this stage.

Man
Manager
Swami Sivananda Memo. Sec. School
(Recognised & Aided)
East Punjabi Bagh, New Delhi-26

Yours faithfully
S 19/11
Chief Fire Officer
Delhi Fire Service