

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001.**

No.F6/DFS/MS/NDZ/2022/ 834

Dated:-13/04/2022

To,

Sh. N. K.Gaur, Fire Officer,  
NDMC, Palika Kendra, New Delhi.

**Sub: Regarding renewal of FSC in r/o Swati Building (hostel), Mandir Marg, New Delhi.**

Sir,

This has reference to your email [nkgaur211@gmail.com](mailto:nkgaur211@gmail.com) dated 16.03.2022 on the subject cited above, it is to inform you that the site was inspected by the officer concerned department on 07/04/2022 in the presence of yourself and the following shortcomings were observed: -

1. Hose reel & hydrant not covering entire floor area in basement.
2. Smoke management system found nonfunctional in basement.
3. Some portion of basement is being used as offices by erecting temporary structure, may lead to life & fire hazard for the person working in office.

In view of above shortcomings, request for renewal of fire FSC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit

Yours faithfully,

  
13/4/22

(Dr. S.K. Tomar )  
**Dy. Chief Fire Officer**  
Delhi Fire Service

Copy to:

The Chief Architect, NDMC, Palika Kendra, New Delhi.