

e-36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/School/2022/186

Dated: 20/04/2022

To

The Principal (1st & 2nd Shift),
EDMC Pratibha Vidhayala,
Vasunshra Enclave,
Delhi - 110096.

**Sub: Regarding grant of FSC in r/o EDMC Pratibha Vidhayala at Vasunshra Enclave,
Delhi - 110096.**


Sir,

This has reference to your email dated 06/04/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 07/04/2022 in the presence of Mr. Maheshwar Prasad (Principal) and observed that following shortcoming was observed :- (Building comprised of Gr. + 02 upper floors)

1. Hose reel hose not functional.
2. Fire pump not functional.
3. Overhead water tank found empty.

Hence, Fire Safety Certificate can not be considered at this stage.

Yours faithfully


(Sunil Chowdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Director of Education,
EDMC, Udyog Sadan,
Plot No. 419, FIE, Patparganj, Delhi-92.

