

c-5

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/Restaurant/2022/NDZ/ 280

Dated: 04/04/2022

To,

Ms. Karishma Jain, Owner
M/s Happy Tummy located
13- UGF, Dayanad Vihar, Near Community Center,
Delhi110092

Sub:- Regarding Issuance of Fire Safety Certificate in r/o M/s Happy Tummy located at 13-UGF, Dayanad Vihar, Near Community Center, Delhi110092.


Sir,

With reference to your online application No. 2022011600828 dated 17/01/22 on the subject cited above. In this connection, it is to inform you that team of officer of this department have carried out the inspection the premises from fire safety point of view in presence of Ms. Karishma Jain, Owner of the premises on dated 12/02/2022. The building comprise of stilt, upper ground plus three upper floors. Proposed eating house is on upper ground floor. Following shortcomings were observed during the time of inspection.

1. First Aid Hose reel is not provided.
2. MOEFA is not provided.
3. Down-comer is not provided.
4. A fire pump having 450 lpm output of 40 meter head at terrace is not provided.
5. Over head tank 20,000 litres is not provided.
6. Exit signage are not provided.

In view of above, the application for issuance Fire Safety Certificate is rejected. The occupancy of building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(Atul Garg)
Director

Copy to:-

The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony,
New Delhi

olc
e

MHA ID No. 2022011600828