

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2022/SZ/ 184

Dated: 20/04/2022

To,


The Manager,
Jyoti Public School,G-2/12,
A-70, Sai Enclave, Mohan Garden,
New Delhi-110059.

Sub:-Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Jyoti Public School,G-2/12,A-70, Sai Enclave, Mohan Garden,New Delhi-110059.

Sir,

This has reference to your letter no. JPS/Mar22/Fire dated 24/03/2022 on the subject captioned above. In this connection, it is to inform you that the above mentioned building/premises was inspected by the officer concerned of this department on 31/03/2022 in the presence of Sh. Ravi Joshi to verify the compliance of shortcoming already communicated by this department vide letter no. F6/DFS/MS/School/2017/SZ/2197 dated 24/08/2017 and observed that shortcomings are still not rectified. The management will be held responsible for any untoward incident for the period if compliance is not made.

Yours faithfully



(Sunil Chawdhary)
Dy.Chief Fire Officer



Copy to:-

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

(With a request to take further action as school does not have fire NOC)

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2017/SZ/2187

Dated: 24/08/17

To,

The Manager,
Jyoti Public School, G-2/12,
A-70, Sai Enclave, Mohan garden,
New Delhi-110059

Sub: - Regarding issuance of Fire Safety Certificate in r/o Jyoti Public School, G-2/12, A-70, Sai Enclave, Mohan garden, New Delhi-110059.

Sir,

This has reference to your Letter No. 29/5/2017 dated 29.05.2017 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 29.6.2017 to see the compliance of the requisite fire safety measures. Sh. Satish Joshi (Manager) was present at the time of inspection.

During the course of inspection it was observed that school building comprised of two blocks namely Block-A & Block-B. Each block is having ground floor plus two upper floors. The upper floors of Block-A are served by two staircases having width 90 cms from Ground floor to second floor and 120 cms from ground floor to first floor. The upper floors of Block-B are served by single staircase having width 146 to 112 cms. The year of construction of the building could not be assessed without providing property documents such as electric bill, telephone bill or house tax receipt etc. Therefore you are advised to provide the same for taking further action as necessary for issuance of Fire Safety Certificate.

In view of above, the issuance of Fire Safety Certificate can not be considered at this stage in the interest of public safety.

Yours Faithfully,

23/8

(VIPIN KENTAL)
CHIEF FIRE OFFICER

21/8/17

Copy to:-

Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054