

c 21

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2022/School/189

Dated: 21/04/2022

To,

The Principal, <greatmission.education@gmail.com>
Rising Star Junior School,
Sector – 10, Dwarka,
New Delhi-110075

Subject: Renewal of Fire Safety Certificate in r/o Rising Star Junior School, Sector –
10, Dwarka New Delhi.

Sir,

Please refer to your Email Dated 21/03/2022 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 05/04/2022.


During the course of inspection following shortcomings are observed.

1. Hose reel hoses found non functional.
2. Terrace Pump found non nonfunctional.
3. Tin shed found erected at terrace.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:- Directorate of Education Old Secretariat Delhi – 110054

1/20/c
18/4