

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F-6/DFS/MS/2022/WZ/ 884

Dated: 22/04/2022

To,

Sh. Amrit Bawa,
Jindal Farm,
Palla Bakhtawarpur Road, Delhi-36.

Sub:- Renewal of Fire Safety Certificate in respect of Jindal Farm located at Palla Bakhtawarpur Road, Delhi-110036.


Sir,

Please refer to your application received via outdoor diary no. 7642 dated 28.03.2022 on the subject cited above. In this connection it is to inform you that the premises was visited by officer concerned of this department on 05.04.2022 in presence of Sh. Ravinder Singh to verify the fire safety arrangements installed. Your request for renewal of Fire Safety Certificate is rejected under sub rule (3) of Rule 37 of Delhi Fire Service Rules 2010, due to following shortcomings.

1. Fire Extinguishers found not functional.
2. First-Aid hose reel found not functional.
3. MOEFA found not functional.
4. Automatic sprinkler system not provided in basement.
5. Internal Hydrant and Yard Hydrant found not functional.
6. Terrace level pump found not functional.
7. Exit signage's found removed.

You are requested to apply again after compliance of the above mentioned shortcomings for further consideration in this matter.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
WEST ZONE

Copy to-

1. The Joint Commissioner of Police, First Floor, Police Station Defence Colony, New Delhi-110049.