

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/2022/

879

22 04
Dated...../...../2022

To,

Sh. G. Onkara,
Chief General Manager,
Power Finance Corporation Ltd. (PFC),
Urjanidhi, 1, Barakhamba Lane,
Connaught Place, New Delhi - 110001.

Sub:-Regarding renewal of FSC in r/o Power Finance Corporation Ltd. (PFC), Urjanidhi, 1, Barakhamba Lane, Connaught Place, New Delhi - 110001.

Sir,

This has reference to your letter no Ref No:02:12:175(1):II:2022:Fire dated 24.03.22 on the subject cited above. In this regard, it is to inform that the site was inspected by the officers concerned of this department on 13/04/2022 in the presence of Sh. G.Onkara, (Chief General Manager), Sh. Jevesh (Manager) and the following shortcomings were observed:-

1. 06-meter road for fire tender movement all around the building found encroached due to parking of vehicles haphazard ally. Further, branches of tree are also required to be pruned for freely movement of fire tender.
2. Back side lift lobby found encroached by dumping storage of various items.

In view of above shortcomings, request for renewal of fire NOC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Garg)

DIRECTOR

Delhi Fire Service

Copy to:

The Chief Architect, NDMC, Palika Kendra, New Delhi.