

12

C/60

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/SZ/2022/ *College & Instt. /13*

Dated: *13/04/2022*

To,

The Executive Engineer (E)  
PWD EMID-M-South,  
Sukhdev Vihar, Mathura Road,  
New Delhi 110025

**Sub:** Regarding renewal of Fire Safety Certificate in r/o Academic Block Dipsar-U, Dipsar, Pushap Vihar, New Delhi

Sir,

This is in reference with Gmail of dated 03/03/2022 on the subject cited above received from Executive Engineer (E) PWD. In this regard, it is informed that the premises have been visited by concerned officer of this department on 04/04/2022 in the presence of Mr. Rakesh. During inspection, it was observed that Basement, Ground plus Seven Upper Floors to verify the compliance of fire prevention and fire safety measures required under the rules. The renewal of FSC is rejected under sub rule (3) of Rule 37, in the view of reasons mentioned below:

1. Fire check doors found removed at some places in basement/ lift lobby/ staircase, self closing device at FCD's are not in working conditions and need repairing / replacement.
2. Smoke management system not working in the basement.
3. The First Aid Hose Reel Hose not working.
4. Detection systems in basement are partially provided (only in lift lobbies areas) and need to be extended in entire basement.
5. MOEFA Not working.
6. Automatic sprinkler systems are covered with fall ceiling at some places.
7. Internal and yard hydrant not working.
8. Fire fighting pumps are not on auto mode.
9. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR /DFS

Copy to:

1. Dr. O.P Shukla, Registrar, DPSRU, at Sector -3, Pushp Vihar M.B Road, New Delhi 110017.