

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

471

No. F6/DFS/MS/GH/NDZ/2022/ 292

Dated: 18/4/2022

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of **M/s Ashirwad Dx. Guest House** situated at **37-38, Church Mission Road, Bagh Diwar, Fatchpuri Delhi.**

Sir,

With reference to online application I.D. no. 2022031603692 dated 16.03.2022 on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 28.03.2022 in the presence Sh. Sandeep (Owner) and it was observed that building is comprised of ground + 03 upper floors. During inspection, following shortcomings were observed.

1. Smoke Management System not provided properly.
2. Fire extinguisher found non functional.
3. First Aid Hose reel found non functional.
4. Public Address System not provided.
5. Fire pump not in auto start mode.
6. Exit Signage not adequately provided.
7. Fire Check door not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
13/4/22  
**((Dr. S.K. Tomar))**

Dy. Chief Fire Officer  
Tel: 011-23412025

011  
12/4

**Copy to:-**

The Licensee,

M/s Ashirwad Dx. Guest House at 37-38, Church Mission Road, Bagh Diwar, Fatchpuri Delhi.