

489

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/2022/290

Dated: 18.04.2022

To,

The Manager,  
Hare Rama Guest House,  
T-416 & T-298, Main Bazar,  
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Hare Rama Guest House located at T-416, & T-298, Main Bazar, Pahar Ganj, New Delhi. Online ID No. 2021101123947 dated 12.10.21.

Sir,

This has reference to on line ID No. 2021101123947 dated 12.10.21 <anup.khanna974@gmail.com dated 24.03.2022, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 06/04/2022 in the presence of Sh. Galid (Manager) and following shortcomings were still not complied: -

1. Fire check door at staircase is not provided as per gazette notification dated 27.05.2019.
2. Smoke management is not provided as per gazette notification dated 27.05.2019
3. CO detectors are not provided as per gazette notification dated 27.05.2019.
4. Building plan is also not signed by the owner /occupier.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcomings for further consideration in the matter.

Yours faithfully,



(Dr. S.K. Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service



Copy to:-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.