

463

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/2022/289

Dated:-18/4/2022

To,

The Manager,
M/S Hotel Sukant Palace Guest House,
1142/10, Abdul Rehman Road, Karol Bagh,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Hotel Sukant Palace Guest House, 1142/10, Abdul Rehman Road, Karol Bagh, New Delhi.

Sir,

This has reference to on-line ID no. 2022022802825 dated 28.02.22 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 05/04/2022 in the presence of Sh. Om Prakash and following shortcomings were observed:

1. Fire check doors are not provided as per gazette notification dated 27.05.2019
2. CO type detectors are not provided as per gazette notification dated 27.05.2019.
3. Hose reel found nonfunctional.
4. Pumps found nonfunctional.
5. MOEFA found nonfunctional.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,



(Dr.S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony, New Delhi.

