

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F6/DFS/MS/2022/WZ/*School/190*

Dated: *21/04/2022*

To,

The Principal,  
Municipal Corporation Primary Girl School,  
Tikri Kalan, New Delhi-110041.

**Subj:- Regarding renewal of Fire Safety Certificate in respect of Municipal Corporation Primary Girl School, Located at Tikri Kalan, New Delhi-110041.**

Sir,

This has reference to your letter no nil dated nil on the subject cited above. In this connection it is to inform you that the said school building was re-inspected by the officer concerned of this department on 24.03.2022 in the presence of Ms. Suman Lata (Principal). Fire Safety arrangement such as fire extinguishers found provided.

**During inspection, the following shortcomings have been observed:-**

1. Two rooms constructed at terrace shall be removed.

In view of the above shortcoming, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Education Authority may take suitable necessary action as deemed fit

Yours faithfully,

*(Signature)*  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054

*21/04/22*  
*21/04/22*