

49

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2022/SZ/292

Dated 13/4/2022

To

The Dy. Health Officer, SDMC,
Public Health Department,
South Zone, Aurobindo Marg,
Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s Perch (A Unit of White Water Café Pvt. Ltd) located at 18A & 18C GF, Mezzanine Floor, Community Center, Basant Lok, Vasant Vihar, New Delhi - 110057

Sir,

This has reference to with MHA Portal ID 2022021902395 dated 19/02/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 02.04.2022 in the presence of Mr. Parveen Kumar (Manager) to verify the fire safety measures installed in the building and observed that the building is comprised of ground + mezzanine + 02 upper floors and restaurant is running at Ground Mezzanine & First floor only. During inspection, following points were observed:

1. There are two staircases having width of 1.25 mtr & 1.05 mtr against the required of having width of 1.50 mtr each as per UBBL 2016.
2. There are two Exits having width of 1.0 mtr each against the required of having width of 1.50 mtr each respectively.
3. The Fire Check Doors not provided.
4. Smoke management system not provided in upper floors.
5. The First aid hose reel not provided.
6. The Internal Hydrant is not provided.
7. One Fire fighting electric pump capacity 2280 LPM with 65m head, one standby fire pump of similar capacity & head and one jockey pump of 180 LPM with head not provided.
8. The underground storage tank of 1, 50,000 ltrs capacity for firefighting not provided.
9. Overhead tank capacity 10,000 ltrs not provided.
10. The standby power supply not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR, DFS

Copy to:

1. The Joint C P (Lic.) P.S. Defence Colony, New Delhi (Ref. MHA Portal ID. 2022021902395 dated 19/02/2022)
2. The Authorized Signature, M/s Perch (A Unit of White Water Café Pvt. Ltd) located at 18A & 18C GF, Mezzanine Floor, Community Center, Basant Lok, Vasant Vihar, New Delhi - 110057

11-2022