

C-82

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/School/2022/191

Dated: 26/4/2022

To

The Principal,
Convent of Jesus and Merry School,
01, Bangla Sahib Road, New Delhi.

**Sub: Regarding issuance /Renewal of FSC in r/o Convent of Jesus and Merry school
Situated at 01 Bangla Sahib Road, New Delhi.**

Sir,

This has reference to your letter no. nil dated 15.03.2022_on the subject cited above. In this regard, it is to inform you that the site was inspected by officers concerned of this department on 24.3.2022 in the presence of Ms. Aarti and the following shortcomings were observed.

1. **Middle School block (B+ Gr. + 2 upper floor)**
 - a. Alternate staircase of .75 m is not provided in the basement.
 - b. Fire check door is not provided in the basement.
2. **Auditorium Block (Basement + Gr. + 03 upper floors)**
 - a. Fire check doors are not provided in the basement.
 - b. Overhead tank capacity is provided 15,000 liter against the requirements of 20,000 liter.

In view of above shortcomings, fire safety certificate (FSC) cannot be renewed/issued at this stage.

Yours faithfully

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:-

The Director of Education,
Govt. of NCT of Delhi, Old Sectt.
Delhi - 54

