

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/OFS/MS/ND2/2022/56

Dated: 25/4/2022

To,

Authorized Signatory,  
Garg Celebration (earlier J.R.P. Vatika Banquet Hall),  
1<sup>st</sup> & 2<sup>nd</sup> Floor, C-24, 25, Acharya Niketan, Opp. Mayur Vihar-1, Delhi-91

**Sub:- Fire Safety Certificate in r/o Garg Celebration (earlier J.R.P. Vatika Banquet Hall) at 1<sup>st</sup> & 2<sup>nd</sup> Floor, C-24, 25, Acharya Niketan, Opp. Mayur Vihar-1, Delhi-91.**

Sir,

Please refer to your letter received through MHA portal application No. 2022040605887 dated 06/04/2022 on the subject noted above, in this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 18/04/2022 in the presence of Sh. Rakesh Garg and following shortcomings were observed during the time of inspection:-

1. Fire check doors found removed.
2. Door Size of 1st Floor are 1.50m & 1.30m and 2nd Floor are 1.80m & 1.30m against requirements of 2m width at each floor.
3. First Aid Hose Reel & Internal Hydrant provided but found nonfunctional.
4. A Fire pump of 450 LPM Provided but found nonfunctional.
5. 2<sup>nd</sup> staircase on ground floor is blocked which should be opened. Also there is meter board and electrical panel board under this staircase / Fire Exit on ground floor which should be replaced.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected.

The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR.

Copy to:-

Joint Commissioner of Police, 1st Floor, PS Defence Colony, New Delhi 110049.  
w.r.t MHA portal ID NO. 2022040605887 dated 06/04/2022.

OKS/A