

C 54

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6 /DFS/MS/GH/NDZ/2022/305

Dated: 22/04/2022

To

The Joint Commissioner of Police,
Office of Joint commissioner of Police: Licensing,
1st Floor, P S Defence Colony, New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Royal Afgan Guest House, G-3663 & 3672, Netaji Subhash Marg, Daryaganj, Delhi.

Sir,

With reference to the online application I.D. no. 2022032804346 dated 28.03.2022 on the subject cited above, it is informed that the said guest house was inspected by Assistant Divisional Officer (SPM) from this department on 18.04.2022 in the presence of Mr. Najeeb, owner and it was observed that the building is comprised of ground + 04 upper floors. During the inspection the following shortcomings were observed: -

1. Fire check door not provided.
2. Public Address system not provided.
3. Fire pump not in auto start mode.
4. Exit signages not provided.
5. Occupancy at fourth floor is not allowed as per gazette notification dated 27.05.2019.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


21/4/22

(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Tel: 011-23412025

82
21/4

Copy to:-

The Licensee,

M/s Royal Afgan Guest House, G-3663 & 3672, Netaji Subhash Marg, Daryaganj, Delhi.