

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/Hospital/2022/SZ/ 896
To

Dated: 22/1/2022

Sng. Mohelas Anal, Estate Officer,
Vardhman Mahavir Medical Collage
& Safdarjung Hospital, New Delhi-110029.

Sub: Issuance of FSC in r/o Emergency Block Safdarjung Hospital located at Safdarjung Hospital Complex, Ring Road, New Delhi.

Sir,

This has reference to your letter no 4-25/Redev/NEB/AMC/Est/2020/357 dated 18/01/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the team of officers from this department on 06.04.2022 along with the representative of HSCC to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observations:-

1. Fire Check doors Closer devise found removed.
2. First aid hose reel provided but not functional.
3. Smoke ventilation system in basement and upper floors not working. The ventilation system shall also be integrated with Fire alarming/ detection system.
4. Automatic fire detection and alarming system provided but not functional.
5. Automatic sprinkler system provided but not functional.
6. Internal and yard hydrants provided but not functional.
7. Fire fighting pumps are not on auto mode. Stand by diesel driven fire pump is not functional.
8. Lift lobby/ Lift well pressurization system is not working.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE