

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/2022/ 947

Dated: 29/04/2022

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/2022/ 947

Dated: 29/04/2022

To

The Executive Engineer (E),
Office of the executive Engineer (E)
Parliament Library Electrical Works Division CPWD,
CPWD Parliament Library Building, Pt. Pant Marg,
New Delhi.

Subject:- Regarding Fire Safety Audit of GMC Balayogi Auditorium at Parliament Library Building, New Delhi

Sir,

This has a reference of your letter No. 23(fire suraksha)/EE (E)/CPWD/2022/126 dated 08.04.2022 on the subject noted above. In this regard it is to inform you that the site was inspected by Divisional Officer (CD) & Assistant Divisional Officer (CC) of this department dated 20/04/2022 in presence of AE(E) & EE/E & AE (Civil) and the following shortcoming are still not complied :-

1. Detectors are not provided in electric room and green room.
2. Gas base suppression system is required to be provided at electric panel for protection.
3. Further, MOEFA also found nonfunctional.

In view of above shortcomings, FSC cannot be renewed. Accordingly, you are requested to rectify the above said shortcomings and inform to us for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:-

1. The Chief Executive Engineer (Elect.) PLEWD, CPWD, Parliament Complex, New Delhi.