

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/School/SZ/2022/ 197

Dated: 29/04/2022

To

The Principal,
Balvantray Mehta Vidya Bhawan Sr. Sec. School,
Lajpat Bhawan, Lajpat Nagar,
New Delhi-24.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **Balvantray Mehta Vidya Bhawan Sr. Sec. School located at Lajpat Bhawan, Lajpat Nagar, New Delhi-24.**

Sir,

With reference to your email dated 01.04.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 13.04.2022 in the presence of Mr. Mukesh Chand, Principal and it was observed that the school building is comprised of ground + 2 upper floors. During the inspection following shortcomings were observed:-

1. 05 no. of fire extinguishers found provided against the requirement of 10 nos. of fire extinguishers.
2. First-aid-hose reels not provided.
3. Fire pump having capacity 450 LPM & head 40 mtrs. not provided.
4. Overhead water tank 10,000 ltrs for firefighting not provided.
5. Exit signages not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Anu Garg)
Director

Delhi Fire Service

Copy to:-

The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony,
New Delhi-24.

o/c
29/4