

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/WZ/EH/2022/305

Dated: 29/04/2022

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlcp.lic-dl@nic.in

Sub: - Inspection report in r/o M/s. Blue Waves (A Unit of Blu Wavs) located at shop no. 19,20,21, 1st floor, TDI Paragon Mall, Rajouri Garden, New Delhi 110027.

Sir,

This is in reference to the online application received through MHA portal vide ID- Online ID 2022022602737 dated 26/02/2022, regarding issuance of Fire Safety Certificate in respect of aforesaid restaurant. In this connection, it is to inform you that the premises was inspected by officers concerned of this department on 04/04/2022 in the presence Sh. Praveen Kumar to check the fire safety arrangements provided in the building.

During the course of inspection, it was observed that the said eating house/restaurant is running at First Floor of TDI Paragon Mall comprised of 02 Basement + Ground + 03 Upper Floor. FSC of TDI Paragon Mall was issued by this department vide letter no. F6/DFS/MS/WZ/2019/1869 dated 27/09/2019. The fire safety arrangements of the restaurant are interlinked with Mall's fire safety system. However, following shortcoming was observed: -

1. Automatic fire detection and alarming system is removed as it is the requirement of Mall.
2. MOEFA is not provided.
3. Exit Signage's are not provided.
4. Width of staircase, No. of staircase, width of corridor uploaded on MHA Portal is not matching with actual requirement.
5. The plan upload on MHA Portal is not signed by the Owner/ Occupier of the restaurant.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisite fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

(Arul Garg)
Director

Delhi Fire Service

Copy to: -

1. The Owner/ Occupier M/s. Blue Waves (A Unit of Blu Wavs) located at shop no. 19,20,21, 1st floor, TDI Paragon Mall, Rajouri Garden, New Delhi 110027. Online ID 2022022602737 dated 26/02/2022
2. The DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id : - (dhowest zone@gmail.com)