

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/School/2022/ 196

Dated: 28/04/2022

To,

The Principal,
Delhi Heritage School,
Main Kanjhawala Road, Sector-22,
Rohini-110085.

Sub: Renewal of Fire Safety Certificate in r/o Delhi Heritage School, Main Kanjhawala Road, Sector-22, Rohini-110085.

Sir,

This is in reference to your letter No. nil dated 07.03.2022 received through outdoor diary no. 7109 dated 07.03.2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **04.04.2022**, in presence of **Smt. Vibha Gupta (Principal)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (4) of Rule 37 of DFS Rules-2010 due to following reason:

1. Fire protection system found disconnected from water tanks in both the blocks.
2. Additional construction found carried out on terrace of third floor of B-block.
3. No ventilation found in staircase of B-Block.

As this is a case of addition/alteration, you are requested to submit sets of building plans on a scale of 1:100 including elevation for entire building through building sanctioning authority i.e MCD/DDA duly marked with fire & life safety provisions as stipulated in NBC for further consideration in this matter.

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

04
04