

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001

No. F6/DFS/MS/2022/Restaurant/NDZ/ 301

Dated: 29/04/2022

To,

The Manager
Dilli Darbar Food Pvt. Ltd.,
Plot no. C-448, 100 Feet road,
Chajjupur, Shahdara delhi

Subject: -Regarding issuance of Fire Safety Certificate in r/o Dilli Darbar Food Pvt.Ltd.
Plot no. C-448, 100 Feet road Chajjupur, Shahdara Delhi.

Sir,

Please refer to your MHA Portal ID.. 2022012601249 dated 27/1/2022 on the subject cited above. In this regard, it is to inform you that, the inspection of the above said premises was carried out by the officer concerned of this department in presence of Mr. Atul Rana, Manager of the Restaurant on dated 16/04/2022. During the inspection it was observed that the shortcomings as communicated earlier vide letter No. F6/DFS/MS/Restaurant/ 2021/NDZ/564 dated 09/12/2021 are yet to be rectified. Copy of the same is enclosed for your ready reference.

Yours faithfully

(Atul Garg)
Director

Copy to:-

1. The Joint Commissioner (Lic.)
1st Floor Police station Defence Colony,
New Delhi.
2. The Commissioner (EDMC)
Plot No. 419, Patparganj Industrial Area,
Delhi-110092.

C-14

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/Restaurant/2021/NDZI/564

Dated: 09/12/2021

To,

Dilli Darbar Food Pvt Ltd.
Plot No. C-448, 100 Feet road
Chajjupur, Shahdara Delhi

Sub:- Regarding Issuance of Fire Safety Certificate in Dilli Darbar Food Pvt Ltd. Plot No. C-448, 100 Feet road Chajjupur, Shahdara Delhi.

Sir,

With reference to your online application No. 20211008173829 dated 14/10/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned restaurant from fire safety point of view in presence of Mr. Atul Rana, (Manager). During the course of inspection the following shortcomings were observed.

1. One Staircase of 1.50 meters is provided instead of two Staircases of 1.50 mtr each.
2. Exit door of 2 mtr & 1.50 mtr wide is not provided.
3. First Aid Hose reel is not provided.
4. MOEFA is not provided.
5. Over head tank 8,000 liter provided in place of 20,000 liter as required.
6. Exit signage's are not provided.
7. Mezzanine floor only have one staircase 1.50 mtr is provided instead of two staircases of 1.50 mtr each.

In view of above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)
Director

Copy to:-

1. The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony,
New Delhi
2. The Commissioner (EDMC)
Plot No 419, Patparganj Industrial Area,
Delhi-110092